



Tom Barrett
Mayor

Bevan K. Baker, FACHE
Commissioner of Health

Vivian T. Chen, MSW, ScD
Health Operations Director

Health Department

Consumer Environmental Health

Frank P. Zeidler Municipal Building, 841 North Broadway, Room 304, Milwaukee, WI 53202-3653 Phone: (414) 286-3674 Fax: (414) 286-5164
web site: www.milwaukee.gov/health

Routine Food Inspection

JIMMY'S LIQUOR LLC
JIMMY'S LIQUOR LLC
6412 N 76TH ST
MILWAUKEE, WI 53223

March 4, 2008

The following list of violations of the Wisconsin Administrative Code as adopted by reference in the Milwaukee Code of Ordinances Chapter 68, and/or other City ordinance(s) must be corrected as soon as possible but not later than the date specified. A re-inspection fee may be assessed if the violation is not corrected by that date. An inspection fee may be charged for any repeat violations.

Fee Amount: **\$0.00**

Code Number	Description of Violation	Correct By
5-202.11	There is no backflow preventer installed on the mop faucet in the restroom. Install a backflow preventer for the mop faucet.	03/04/2008
8-301.11	There is no self closing unit installed for the restroom door. All restroom doors must self close when opened. Install a self closing unit for the restroom door.	03/04/2008

Inspection Notes

The upright refrigerator is approved for use conditionally. Keep the refrigerator clean and in good working order. When the refrigerator fails or if the refrigerator is not kept clean and in good condition, an approved NSF or Sanitation listed unit will need to be purchased to replace it.

On 3/4/2008, I served these orders upon JIMMY'S LIQUOR LLC by leaving this report with

Inspector Signature (Inspector ID: 66)

Operator Signature

Please be advised that this document is subject to public review under open records law. - Wis. Statutes section 19.35(1)(a)